



Liquid Nitrogen Bulk Storage Maintenance

Kenneth Anderle

September 19, 2016



Agenda



- Purpose
- Background
- Scope
- Work Completed
- Findings/Lessons Learned
- Path Forward
- Recommendations
- Questions



Purpose



- **During fiscal year 2016, we started a major maintenance project on our 6 bulk storage Liquid Nitrogen tanks at JSC.**
 - **Primary Goal: Improve efficiency of tank vacuum annulus (eliminate leaks).**
 - **Secondary Goal: Check condition of perlite insulation and system components.**





Background



- Over the period of 6 months after cleaning tank exterior, multiple tanks saw steady increase in pressure on vacuum annulus.
- During test in Chamber A, one of the LN2 bulk storage tanks lost vacuum on the annulus.
 - Vacuum pressure steadily rose over 2 days
 - Vacuum pump eventually overcome and failed
 - LN2 had to be transferred out of tank

Project Scope

- Replace vacuum pipe spools from vacuum pumps to main tanks



Project Scope

- Replace positive pressure relief devices on 2 tanks (vacuum side).




Project Scope

- Replace other leaking and leak-prone components.






Work Completed

- Vacuum pipe spools replaced (all 6 tanks).
 - Mechanical joints/connections minimized
 - Unnecessary components eliminated



Work Completed

- Replaced non-vacuum valves on various ports
- Added new vacuum sensor ports
- Capped/sealed extraneous ports
- Replaced manual vacuum isolation valves
- Replaced solenoid vacuum isolation valves





Findings/Lessons Learned



- Years of leaks (masked by continuous pumping) resulted in large accumulation of water in annulus
 - Inner vessel acted as a cryo-pump for water until becoming saturated
 - Removing water to bring tanks back online has been a challenge
 - Heating inner vessel to 100+°C
 - LN2 cold trap on vacuum line
- Additional leaks found on pressure
- relief devices for remaining 4 tanks
 - Utilize burst disks in conjunction with
 - check valves in event of valve failure
 - Also determined relief devices under-
 - sized in event of inner vessel rupture.





Findings/Lessons Learned



- Solenoid valves designed to close in the event of vacuum pump failure or power loss were not functioning properly
 - Resulted in back-streaming of oil into vacuum annulus
- Periodic tank warm-up to be added to preventive maintenance schedule
 - GN2 purge and sampling for moisture and hydrocarbons
 - Helium leak checks



Path Forward

- Replace check valves on remaining 4 tanks with lift plates
 - Meeting relief requirements requires additional devices be installed
 - Multiple flanges on top of tanks available
 - Excessive corrosion on flanges requires stud extraction & resurfacing





Recommendations



- What is the status of the vacuum annulus on your tanks?
 - What level of monitoring do you have?
 - Would it alert you of a leak?
 - Periodic helium leak checks
- What is the condition of the positive pressure relief devices on the vacuum side of your tanks?
 - Are they periodically checked? (probably exempt since they're on a vacuum system...)



Questions

